Communication Schemes for Centralized and Decentralized Event-Triggered Control Systems

Sokratis Kartakis, Anqi Fu Student Member, IEEE,

Manuel Mazo, Jr. Member, IEEE, and Julie A. McCann Member, IEEE

Abstract-Energy constraint long-range wireless sensor/ actuator based solutions are theoretically the perfect choice to support the next generation of city-scale cyber-physical systems. Traditional systems adopt periodic control which increases network congestion and actuations while burdens the energy consumption. Recent control theory studies overcome these problems by introducing aperiodic strategies, such as event-triggered control. In spite of the potential savings, these strategies assume actuator continuous listening while ignoring the sensing energy costs. In this paper, we fill this gap, by enabling sensing and actuator listening duty-cycling and proposing two innovative MAC protocols for three decentralized event-triggered control approaches. A laboratory experimental testbed, which emulates a smart water network, was modelled and extended to evaluate the impact of system parameters and the performance of each approach. Experimental results reveal the predominance of the decentralized event-triggered control against the classic periodic control either in terms of communication or actuation by promising significant system lifetime extension.

Index Terms—Event-Triggered Control, Communication Protocols, Cyber-Physical Systems, Wireless Sensor/Actuator Networks, Networked Control Systems.

I. INTRODUCTION

Over the last decade, there has been a growing trend in industry to transform large-scale manual control and monitoring systems, such as electrical grids and water networks, into fully automatic Cyber-Physical Systems (CPS). The aim of this transformation is the improvement of quality of service and reduction of maintenance cost. In order to achieve these goals, plants and physical environments have been augmented with sensor and actuator nodes which enable monitoring and control by communicating wirelessly and periodically to data centres or local base stations. However, these periodic dynamic control implementations introduce communication and energy consumption overheads.

In large scale CPS, sensor and actuator nodes are usually energy constraint and installed in harsh environments. For example, in smart water network more than 97% of sensing and actuation assets are located underground and powered by batteries [1]. To transmit the required information through long-range (several kilometres) wireless communications, high transmission power is required that leads to fast battery depletion. In addition, the periodic sensing, transmission, and actuation, regardless the state of the plant, decreases network bandwidth and increases actuations and consequently the energy consumption. Recent control theory studies propose to solve these problems by introducing aperiodic strategies, such as Event-Triggered Control (ETC) strategies, e.g. [2]–[7] in which the sensors and actuators communicate only when necessary.

In spite of the potential of significant savings, ETC techniques have only been partially examined and implemented on real systems, i.e. [8]–[19]. In [10], the authors propose a system based on the Diddyborg robot and examine the strategy presented in [7]. However, this system is first-order and therefore unable to test complex event-triggered strategies. In [19], an experimental evaluation was made for time-triggered control and event-triggered control from [2]. However, this work requires state monitoring continuously to check event conditions. Additionally, the results in [2] can only be used for system with collocated sensors. To the best of our knowledge, there is no experiment that validates and compares different decentralized event-triggered mechanisms under the same conditions.

ETC systems have been studied extensively in order to guarantee convergence of plants under reduced communication schemes. However, the design and implementation of a communication protocol, which fully exploits the ETC behavior and ensures optimal communication, is still missing [20]. State of the art ETC approaches that are focused on communication, i.e. [21]-[29], have been limited to simulate or analyze theoretically the impact of network states on system performance. CSMA [30], TDMA [31] and ALOHA [32] were the three communication protocols which have been used in the above approaches. Specifically, [21], [22] provide useful insights and comparison of all the above communication protocols. The authors in [23]-[25] present a Markov model that captures the joint interactions of the event-triggering policy and a contention resolution mechanism over CSMA communication. In [26], [27], the ALOHA protocol, which has been applied in Long Term Evolution (LTE) Random Access (RA) procedure, was combined with ETC, with [27] to introduce the impact of collisions into the system performance. TDMA-based communication protocols, i.e. Time Triggered Network-on-a-Chip (TTNoC), Time Triggered Controller Area Network (TTCAN), were analysed in [28], which discusses their application to ETC systems. The earliest practical work is [19], continued in [29], by proposing the extension of the

S. Kartakis (*corresponding author*) was with the Department of Computing, Imperial College London, London SW72AZ, UK. He is now with the Intel Labs Europe, London E145EJ, UK (e-mail: sokratis.kartakis@intel.com).

A. Fu and M. Mazo Jr. are with the Delft Center for Systems and Control, Delft University of Technology, Delft 2628CD, The Netherlands (e-mail: {a.fu-1, m.mazo}@tudelft.nl).

J. A. McCann is with the Department of Computing, Imperial College London, London SW72AZ, UK (e-mail: j.mccann@imperial.ac.uk).

TDMA-based IEEE 802.15.4 MAC layer [33] which has been used in communication protocols for network control via wireless, i.e. WirelessHART [34]. However, the main drawbacks of this approach are the assumption that the actuator nodes listen continuously to network messages. Furthermore, none of the prior work has considered the cost of sensing. For example, in our evaluation platform [35], the sensing costs almost the half the energy consumption of communication. In industrial systems with more energy hungry sensors, e.g. laser based turbidity sensors for water quality, the energy cost may surpass communications.

Note that ETC is different than similar proposals on the communications domain, e.g. [36]. Such event-based communications are data-driven techniques aimed at increasing also network energy efficiency. However, such techniques are oblivious of any requirements to guarantee stability in a real-time control application. In contrast, ETC approaches provide pre-designed stability and performance guarantees while reducing resources' consumption.

Uniquely, in this paper, the proposed system avoids continuous sensing and state transmission from the sensor nodes, as well as radio listening for new control signals from the actuator nodes. These goals are achieved by applying periodic decentralized event-triggered control strategies combined with innovative TDMA-based communication schemes.

Specifically, the contributions of this paper are listed as follows:

- Practical combination of sensor duty-cycling with three decentralized aperiodic control approaches.
- A new MAC protocol that facilitates decentralized synchronous ETC without the requirement of continuous actuator communication.
- A novel flexible MAC protocol that can also accommodate two decentralized and asynchronous ETC approaches, communicating firstly absolute states and alternatively relative states only.

By using an extended version of the WaterBox testbed environment [35], we provide experimental results from Time-Triggered Control (TTC) and four different ETC techniques: Periodic centralized ETC (PETC) [4], Periodic Synchronous Decentralized ETC (PSDETC) [5], and Periodic Asynchronous Decentralized ETC (PADETC) by transmitting absolute or relative state [37]. To the best of our knowledge, this is the first real deployment of most of the implemented ETC techniques to a real plant.

II. EVENT-TRIGGER CONTROL TECHNIQUES

We denote the positive real numbers by \mathbb{R}^+ , the natural numbers including zero by \mathbb{N} . $|\cdot|$ denotes the Euclidean norm in the appropriate vector space, when applied to a matrix $|\cdot|$ denotes the l_2 induced matrix norm. A matrix $P \in \mathbb{R}^{n \times n}$ is said to be positive definite, denoted by $P \succ 0$, whenever $x^{\mathrm{T}}Px > 0$ for all $x \neq 0, x \in \mathbb{R}^n$. For the sake of brevity, we write symmetric matrices of the form $\begin{bmatrix} A & B \\ B^{\mathrm{T}} & C \end{bmatrix}$ as $\begin{bmatrix} A & B \\ \star & C \end{bmatrix}$.

A. Periodic control

Consider a linear time-invariant (LTI) plant [38] and controller

$$\xi(t) = A\xi(t) + Bv(t), \tag{1}$$

$$v(t) = K\xi(t),\tag{2}$$

where $\xi(t) \in \mathbb{R}^n$ is the state vector and $v(t) \in \mathbb{R}^m$ is the input vector at time t. Assume A + BK is Hurwitz, the system is completely observable, and each sensor can access only one of the system states.

A sample-and-hold mechanism is implemented for the controller (2):

$$v(t) = K\xi(t), \tag{3}$$

where

$$\xi(t) := \xi(t_b), t \in [t_b, t_{b+1}].$$
 (4)

and $\{t_b\}_{b\in\mathbb{N}}$ is the sequence of the update time of the state. Representing the sample-and-hold effect as a measurement error, we have:

$$\varepsilon(t) := \xi(t) - \xi(t). \tag{5}$$

Define T as the sample period. In a periodic time-triggered control strategy, t_b is determined by

$$\{t_b | t_b = bT, b \in \mathbb{N}, T > 0\}.$$
(6)

B. Periodic centralized event-triggered control

In event-triggered control strategies, the control input update time is determined by some pre-designed conditions. These conditions usually involve the system state and sample-andhold error (5), e.g. [2]–[5]. Therefore, control executions happen only when necessary. However, the centralized eventtriggered condition presented in [2] requires the continuous monitoring and transmission of the current state to check the event conditions. If the state cannot be measured continuously, we can either compute a stricter event condition considering measurement delays; or apply the PETC strategy from [4], which combines periodic sampled-data control and eventtriggered control:

Consider system (1), (3), (5), and a sample sequence (6). At each sampling time t_b , the controller updates its state by

$$\hat{\xi}(t_b) = \begin{cases} \xi(t_b), \text{ when } \xi_p^{\rm T}(t_b) Q \xi_p(t_b) > 0\\ \hat{\xi}(t_{b-1}), \text{ when } \xi_p^{\rm T}(t_b) Q \xi_p(t_b) \le 0, \end{cases}$$
(7)

where $\xi_p(t) = \begin{bmatrix} \xi^{\mathrm{T}}(t) & \hat{\xi}^{\mathrm{T}}(t) \end{bmatrix}^{\mathrm{T}}$, Q satisfies $Q := \begin{bmatrix} (1-\sigma)I & -I \\ -I & I \end{bmatrix}$, and $\sigma > 0$. For the system (1), (2), (5), q = 1, (6), (7), $\overline{q} = 1$.

For the system (1), (3), (5), and (6), if $\exists c > 0$ and $\rho > 0$ such that for any initial condition $\xi(0) \in \mathbb{R}^n$, $\forall t \in \mathbb{R}^+$, $|\xi(t)| \leq ce^{-\rho t} |\xi(0)|$ is satisfied, then the system is said to be globally exponential stable, we call ρ the decay rate [39].

According to Corollary III.3 in [4], given a decay rate $\rho > 0$, if there exist a matrix $P \succ 0$ and scalars $\mu_i \ge 0$, $i \in \{1, 2\}$, such that

$$\begin{bmatrix} e^{-2\rho T}P + (-1)^{i}\mu_{i}Q & J_{i}^{\mathrm{T}}e^{\bar{A}^{\mathrm{T}}T}P\\ \star & P \end{bmatrix} \succ 0, \, i \in \{1, 2\}, \quad (8)$$

where

$$\bar{A} := \begin{bmatrix} A & BK \\ 0 & 0 \end{bmatrix}, J_1 := \begin{bmatrix} I & 0 \\ I & 0 \end{bmatrix}, J_2 := \begin{bmatrix} I & 0 \\ 0 & I \end{bmatrix},$$

then the system is globally exponential stable with a decay rate ρ .

C. Periodic synchronous decentralized event-triggered control

The event-triggered strategies presented in (7) are centralized event-triggered strategies, since the event conditions require the whole vector of current state and current error. When the sensors are not co-located, decentralized event conditions are preferred. We introduce the PSDETC strategy based on [5].

For system (1), (3), and (5), a decentralized event-triggering condition with periodic sampling (6) is given by:

$$\hat{\xi}(t_b) = \begin{cases} \xi(t_b), \text{ when } \exists i : \varepsilon_i^2(t_b) - \sigma \xi_i^2(t_b) > \theta_i \\ \hat{\xi}(t_{b-1}), \text{ when } \forall i : \varepsilon_i^2(t_b) - \sigma \xi_i^2(t_b) \le \theta_i, \end{cases}$$
(9)

where $\varepsilon_i(t)$ and $\xi_i(t)$ denote the *i*-th coordinates of $\varepsilon(t)$ and $\xi(t)$ respectively, and $\{\theta_i\}_{i \leq n}$ is a set of parameters. Define $\{t_k\} := \{t_b | \exists i, \varepsilon_i^2(t_b) - \sigma \xi_i^2(t_b) > \theta_i\}$ the sequence of event times. The sequence $\{\theta_i\}_{i \leq n}$ is obtained solving at each event time t_k :

$$\begin{cases} \hat{G}_{i}(t_{k}+t_{e}) = \hat{\varepsilon}_{i}^{2}(t_{k}+t_{e}) - \sigma \hat{\xi}_{i}^{2}(t_{k}+t_{e}) - \theta_{i}(k) \\ \hat{G}_{i}(t_{k}+t_{e}) = \hat{G}_{j}(t_{k}+t_{e}), \, \forall i, j \in \{1, 2, \cdots, n\} \\ \sum_{i=1}^{n} \theta_{i}(k) = 0, \end{cases}$$
(10)

where for $t \in [t_k, t_{k+1}[$

$$\begin{aligned} \hat{\xi}_i(t) &= \xi_i(t_k) + \dot{\xi}_i(t_k)(t - t_k) + \frac{1}{2} \ddot{\xi}_i(t_k)(t - t_k)^2 + \dots \\ &+ \frac{1}{q!} \xi_i^{(q)}(t_k)(t - t_k)^q \\ \hat{\varepsilon}_i(t) &= 0 - \dot{\xi}_i(t_k)(t - t_k) - \frac{1}{2} \ddot{\xi}_i(t_k)(t - t_k)^2 - \dots \\ &- \frac{1}{q!} \xi_i^{(q)}(t_k)(t - t_k)^q. \end{aligned}$$

The map $t_e : \mathbb{N} \to \mathbb{R}^+$ can be set to either $t_e(k) = T$ or $t_e(k) = t_k - t_{k-1}$. We apply Algorithm 1 in [5] to determine $t_e(k)$ in the experiments.

Thus, with the current $\theta_i(k)$ being calculated and transmitted from the controller to each sensor node, the sensor node can locally determine the occurrence of local events. When there is an event, the corresponding sensor node notifies the controller, and then the controller requests fresh measurements from all sensors to compute and update the control input.

Proposition 1. For system (1), (3), (5), and (9), given a decay rate $\rho > 0$, if there exist a matrix $P \succ 0$ and scalars $\mu_1, \mu_2, \mu_3 \ge 0$, such that

$$\begin{pmatrix}
\begin{bmatrix}
e^{-2\rho T}P - \mu_1 Q & J_1^{\mathrm{T}} e^{\bar{A}^{\mathrm{T}}T}P \\
\star & P
\end{bmatrix} \succ 0 \\
\begin{bmatrix}
e^{-2\rho T}P + \mu_2 Q & J_2^{\mathrm{T}} e^{\bar{A}^{\mathrm{T}}T}P \\
\star & P
\end{bmatrix} \succ 0 \\
\begin{bmatrix}
e^{-2\rho T}P + \mu_3 Q & J_1^{\mathrm{T}} e^{\bar{A}^{\mathrm{T}}T}P \\
\star & P
\end{bmatrix} \succ 0,$$
(11)

hold, then the system is globally exponential stable with a decay rate ρ .

Proof: According to [5], $\forall i : \varepsilon_i^2(t) - \sigma \xi_i^2(t) \leq \theta_i$ implies $\varepsilon^{\mathrm{T}}(t)\varepsilon(t) \leq \sigma \xi^{\mathrm{T}}(t)\xi(t)$, which is equivalent to $\xi_p^{\mathrm{T}}(t_b)Q\xi_p(t_b) \leq 0$. However, $\exists i : \varepsilon_i^2(t) - \sigma \xi_i^2(t) > \theta_i$ may indicate $\xi_p^{\mathrm{T}}(t_b)Q\xi_p(t_b) > 0$ or $\xi_p^{\mathrm{T}}(t_b)Q\xi_p(t_b) \leq 0$. From the proof of Corollary III.3 in [4], if the hypothesis in Proposition 1 hold, by applying the S-procedure (see e.g. [40]), one obtains

$$x^{\mathrm{T}}Qx > 0$$
 holds, then $W(J_1x, 0) \leq W(x, T)$,
 $x^{\mathrm{T}}Qx \leq 0$ holds, then $W(J_2x, 0) \leq W(x, T)$,
 $x^{\mathrm{T}}Qx \leq 0$ holds, then $W(J_1x, 0) \leq W(x, T)$.

in which $W(x,\tau)$ is a Lyapunov function defined as (18) in [4]. Therefore, W does not increase during samplings. Together with the results from Theorem III.2 in [4] that, such a P can guarantee $\frac{d}{dt}W \leq -2\rho W$ between samplings, the system is globally exponential stable with a decay rate ρ .

D. Periodic asynchronous decentralized event-triggered control

A periodic asynchronous event-triggered control strategy is presented in [37]. In this strategy, again the triggering condition is distributed to each sensor node. When there is an event, in contrast with PSDETC, only the corresponding sensor node data is used to update the controller. The updated control input is then calculated and transmitted to the actuators.

Remark. In [37], the periodic asynchronous event-triggered mechanism requires **only** the transmission of the relative value of the state (i.e. increment and sign). In this paper, we call this mechanism PADETCrel. Additionally, we introduce the PADETCabs mechanism in which the nodes transmit the state (or absolute value) of the plant.

Consider system (1), (3), and (5), the current sampled state in the controller is updated as:

$$\hat{\xi}_i(t_b) = \begin{cases} q(\xi_i(t_b)), \text{ if } i \in \mathcal{J} \\ \hat{\xi}_i(t_{b-1}), \text{ if } i \in \mathcal{J}_c, \end{cases}$$
(12)

where q(s) denotes a quantized signal of s, \mathcal{J} is an index set: $\mathcal{J} \subseteq \{1, \dots, n\}$ for $\xi(t)$, indicating the occurrence of events, $\mathcal{J}_c := \{1, \dots, n\} \setminus \mathcal{J}$.

Define $\Gamma_{\mathcal{J}} := \operatorname{diag}(\gamma_{\mathcal{J}}^1 \cdots, \gamma_{\mathcal{J}}^n)$. The element $\gamma_{\mathcal{J}}^l$, with $l \in \{1, \cdots, n\}$ is equal to 1, if $l \in \mathcal{J}$, and 0 otherwise. Furthermore, we use the notation $\Gamma_j = \Gamma_{\{j\}}$. The local event-triggering condition is:

$$i \in \mathcal{J} \text{ iff } \xi_p^{\mathrm{T}}(t_b) Q_i \xi_p(t_b) \ge \eta_i(t_b),$$
 (13)

where $Q_i := \begin{bmatrix} \Gamma_i & -\Gamma_i \\ -\Gamma_i & \Gamma_i \end{bmatrix}$, $\eta_i(t) := \omega_i^2 \eta^2(t)$ is a local threshold, ω is a pre-designed distributed parameter satisfying

 $|\omega| = 1$, $\eta(t)$ is a global threshold, determined by

$$\eta(t_b^+) = \begin{cases} \mu\eta(t_b), \text{ if } |\hat{\xi}(t_b^+)| \leq \varrho\eta(t_b) \wedge \eta(t_b) > \mu^{-1}\eta_{\min}, \\ \eta_{\min}, \text{ if } |\hat{\xi}(t_b^+)| \leq \varrho\eta(t_b) \wedge \eta(t_b) \leq \mu^{-1}\eta_{\min}, \\ \mu^{-1}\eta(t_b), \text{ if } |\hat{\xi}(t_b^+)| \geq \mu^{-1}\varrho\eta(t_b), \\ \eta(t_b), \text{ otherwise}, \end{cases}$$
(14)

where $\eta_{\min} > 0$ is a pre-specified minimum threshold, $\mu \in]0, 1[$ is a pre-designed parameter, and ϱ is a design parameter which can be determined by validating the feasibility of some bilinear matrix inequalities (17).

Consider the Hamiltonian matrix:

$$H := \begin{bmatrix} H_{11} & H_{12} \\ H_{21} & H_{22} \end{bmatrix},$$
 (15)

where $H_{11} := \overline{A} + \rho I$, $H_{12} := 0$, $H_{21} := -(\gamma^2 I - I)^{-1}$, $H_{22} := -(\overline{A} + \rho I)^{\mathrm{T}}$, for some $\gamma > 1$, and some given $\rho > 0$. And introduce the matrix exponential

$$F(\tau) := e^{-H\tau} = \begin{bmatrix} F_{11}(\tau) & F_{12}(\tau) \\ F_{21}(\tau) & F_{22}(\tau) \end{bmatrix}.$$
 (16)

Assumption 1. $F_{11}(\tau)$ is invertible $\forall \tau \in [0, T]$.

Base on [4], if Assumption 1 holds, then the matrix $-F_{11}^{-1}(T)F_{12}(T)$ can be guaranteed to be positive semidefinite. Define the matrix \bar{S} satisfying $\bar{S}\bar{S}^{T} := -F_{11}^{-1}(T)F_{12}(T)$.

According to Theorem IV.4 in [37], consider the system (1), (3), (5), (12), and (14), given the Assumption 1 holds and a decay rate $\rho > 0$. If there exist matrix $P \succ 0$, scalars $\varrho > 0$, $\beta_1 > 0$, $\beta_2 > 0$ and $\epsilon_{\mathcal{J}_i} > 0$, $\mathcal{J} \subseteq \{1, \dots, n\}$, $i \in \{1, \dots, n\}$ such that the bilinear matrix inequality

$$\begin{bmatrix} \beta_2 I & F_{11}^{-T}(T) P \bar{S} & \bar{F} & -\beta_2 J_{\mathcal{J}} & 0\\ \star & I - \bar{S}^T P \bar{S} & 0 & 0 & 0\\ \star & \star & \bar{F} & 0 & 0\\ \star & \star & \star & P + \tilde{H}_1 & 0\\ \star & \star & \star & \star & \tilde{H}_2 \end{bmatrix} \succ 0, \quad (17)$$

holds, where

$$\begin{split} \tilde{F} &:= F_{11}^{-\mathrm{T}}(T) P F_{11}^{-1}(T) + F_{21}(T) F_{11}^{-1}(T) \\ \tilde{H}_{1} &:= -\beta_{1}I + \beta_{2}J_{\mathcal{J}}^{\mathrm{T}}J_{\mathcal{J}} - \sum_{i\in\mathcal{J}}\epsilon_{\mathcal{J}_{i}}Q_{i} + \sum_{i\in\mathcal{J}_{c}}\epsilon_{\mathcal{J}_{i}}Q_{i} \\ \tilde{H}_{2} &:= \beta_{1}\varrho^{2}I - \beta_{2}\bar{\Delta}_{\mathcal{J}}^{\mathrm{T}}\bar{\Delta}_{\mathcal{J}} + \sum_{i\in\mathcal{J}}\epsilon_{\mathcal{J}_{i}}\Theta^{\mathrm{T}}\Gamma_{i}\Theta \\ - \sum_{i\in\mathcal{J}_{c}}\epsilon_{\mathcal{J}_{i}}\Theta^{\mathrm{T}}\Gamma_{i}\Theta \\ \bar{\Delta}_{\mathcal{J}} &:= \begin{bmatrix} 0 \\ \Gamma_{\mathcal{J}}\Theta \end{bmatrix}, J_{\mathcal{J}} = \begin{bmatrix} I & 0 \\ \Gamma_{\mathcal{J}} & I - \Gamma_{\mathcal{J}} \end{bmatrix} \\ \Theta &= \begin{bmatrix} \omega_{1} & \cdots & \omega_{n} \end{bmatrix}^{\mathrm{T}}, \end{split}$$

then $\mathcal{A} := \{x | |x| \leq \bar{\varrho}\eta_{\min}\}$ is a globally pre-asymptotically stable set for the system (see e.g. [41]), where $\bar{\varrho} := \max\{|J_{\mathcal{J}}|\varrho + |\bar{\Delta}_{\mathcal{J}}|, \forall \mathcal{J}\}$. Intuitively, the globally preasymptotically stability indicates that the hybrid system state converges to a set along the hybrid timeline. This set is the globally pre-asymptotically stable set. In [37], the update of the signals $\hat{\xi}_i(t_b)$ is given by:

$$\hat{\xi}_i(t_b) = \hat{\xi}_i(t_{b-1}) + \operatorname{sign}(\hat{\xi}_i(t_{b-1}) - \xi_i(t_b))m_i(t_b)\sqrt{\eta_i(t_b)},$$
(18)

in which $m_i(t_b) := \lfloor \frac{|\hat{\xi}_i(t_{b-1}) - \xi_i(t_b)|}{\sqrt{\eta_i(t_b)}} \rfloor$, $i \in \{1, \dots, n\}$. Thus, in practise, the sign $(\hat{\xi}_i(t_{b-1}) - \xi_i(t_b))$ and $m_i(t_b)$ has to be transmitted from the sensor to the controller. The increment and sign represent the relative value in PADETCrel. In PADETCabs, the signals $\hat{\xi}_i(t_b)$ is instead updated by $\hat{\xi}_i(t_b) = \xi_i(t_b)$. Note that, all the ETC mechanisms have a fine static quantizer due to the analogue to digital conversion. In PADETCrel, the sensor nodes transmit only the relative state. Therefore, an additional coarse dynamic quantizer can be applied with maximum quantization error $\sqrt{\eta_i(t_b)}$ for each sensor, i.e. let $q(\xi_i(t))$ in (12) be of the form shown in (18). However, since the fine static quantizers we install in our experimental setting have quantization error negligible compared to the noise, only PADETCrel considers the output quantization error.

III. INCORPORATING ETC WITH THE MAC LAYER



Figure 1: Network architecture.

In this section, we present the design and implementation of three innovative TDMA-based MAC protocols which enable the deployment of TTC, PETC, PSDETC, and PADETC approaches accordingly: Control-TDMA (C-TDMA), Synchronous Decentralized-CTDMA (SDC-TDMA), and Asynchronous Decentralized-CTDMA (ADC-TDMA). The main benefits of these ETC-specific MAC protocols are: the optimization of communications by fully exploiting the behaviour and needs of ETC; the minimization of actuator node listening through duty cycling; and the off-load of the local controller node by allowing **only** one node to communicate with a base station per time.

For the proposed TDMA-based communication schemes, we assume a city-scale CPS network infrastructure, such as in Figure 1, which represents a smart water network. In this architecture, the sensors and actuators are divided into clusters. Each clusters consists of only the sensors, actuators, and a base station which are involved in the control loop of an application for a specific area. The sensor/actuator nodes communicate in single-hop¹ with a base station and retrieve acknowledgement messages per transmission. Based on this architecture, we assume a star topology in which all the nodes of the same cluster can communicate with the base station (in which the controller is running) of the cluster. Contemporary long-range communication technologies, such as low-power wide-area (LPWA) [42], are representative examples of embodiments this architecture. Further, the controller which computes the control signals is executed in the base station. In this paper, the terms controller and base station are used interchangeably. Our communication schemes are applied within each cluster while the the information exchange among different clusters is out of the scope of this work. Note that, despite the single-hop and centralized communication, the triggering of state transmission is distributed for decentralized ETC mechanisms.

A. Simplistic TDMA Protocol



Figure 2: Simplistic TDMA MAC Protocol.

TDMA is a channel access method for shared medium networks, which allows several users to share the same frequency channel. Specifically, time is divided into intervals T_i with length T, so-called super-frames. Each interval is split into smaller time slots S_j , with $\sum_{j=1}^N S_j \leq T$, where N is the number of sensor/actuator nodes which share the same channel². In each time slot, only one predefined sensor/actuator node N_j can transmit (T_x) or receive (R_x) a burst of messages to and from a base station. Outside the timeslot S_j , N_j sleeps or executes other tasks depending on the hardware infrastructure and the provided ability to duty cycle. To avoid time violations of time slot bounds due to N_j possible clock drift, a guard slot forces the termination of communication before the end of each S_j . Figure 2 illustrates the communication scheme of a simplistic TDMA protocol.

Due to synchronous operation, a TDMA-based protocol (e.g. [34]) can guarantee tight bounds on delays which are critical for network control systems. On the other hand, synchronizing sensor/actuator nodes is considered as the main

drawback of TDMA-based systems. However, state of the art solutions, i.e. GPS clock synchronization technologies [43], ensure typical accuracy better than 1 microsecond by consuming ultra low power and without introducing communication overheads. This time synchronization technology has been tested widely, in term of robustness and performance, in real city-scale deployments, such as the smart water network in [44].

B. C-TDMA and TTC & PETC



Figure 3: CTDMA protocol.

Control-TDMA (C-TDMA) is designed to enable TTC and PETC approaches (see Figure 3). In order to ensure the simultaneous state sampling, in the beginning of every interval T_i at time t_i , every node N_j has to retrieve a state measurement x_j from the available sensors. Then, the channel bandwidth is divided into two sets of time slots which are separated by a time delay:

1) Measurement Slots S_j^x (X-slots): Every sensor/actuator node N_j transmits x_j within the time slot S_j^x to the controller. Within each time slot only one successful message is required. Thus, the size selection of S_j^x is application specific and depends on the size of x_j (e.g. 2 Bytes per sensor) and the number of re-transmissions to achieve high reliability based on the selected hardware.

2) **Delay** $\mathbf{d_c}$: After receiving the complete sampled state by receiving $x_j, \forall j \in N$, a time delay is required to allow the computation of appropriate control signals u_j for every sensor/actuator node N_j . The length of this delay depends on the controller infrastructure and the complexity of the control model.

3) Actuation Slots S_j^u (U-slots): The last set of time slots is related to the control message retrieval by the sensor/ actuator nodes N_j . In each time slot S_j^u , node N_j transmits a request r_j for a control signal u_j to the controller. Then, the u_j is piggybacked to the acknowledgement message. The benefit of the r_j request is two-fold: (a) off-loads the controller side and (b) reduces N_j listening time. Otherwise, the controller has to transmit or broadcast u_j continuously by blocking other tasks, while N_j has to be active in receive mode during the full length of the S_j^u slot until a successful control message retrieval. Further, this approach causes more energy savings for nodes with communication modules that consume the same amount of energy for transmission and listening, i.e. [45]. The length of S_i^u depends on the size of u_j signals.

¹We selected a single-hop communication because a dynamic multi-hop network infrastructure cannot provide guarantees for time delays; a critical factor for control systems.

²A super-frame can be divided into equal time slots that fully utilize the channel or to minimal slots which cover the application requirements and allow the communication to new nodes into the same channel.



(a) SDC-TDMA Protocol for PSDETC approach.

(b) ADC-TDMA Protocol for PADETC approach.

Figure 4: Communication schemes for decentralized ETC techniques.

Based on the above, the minimum interval size T_{min} can be defined by the length of X-slots, U-slots and delay d_c , and the number of the nodes. Further, the T_{min} can be considered as the maximum time delay of the system.

TTC and PETC are centralized approaches and are executed in the controller. In both cases, the system requires the transmission of the current state to the controller at every T_i during the X-slots. Then, in the TTC technique, the controller replies back in the U-slots of every interval T_i with a new u_j control signal. On the other hand, in PETC, the controller evaluates the event condition, as has been described in Equation (7), and transmits the new u_j only if there is a violation. This behaviour allows PETC to save energy due to actuation reduction. Note that the base-station has only as extra overhead the evaluation of the event-triggered condition in Equation (7). Therefore, the introduced computational complexity is minor compared to that of TTC systems.

C. SDC-TDMA and PSDETC

PSDETC is a distributed technique and each sensor node is responsible for the state transmission decision in every T_i . The computation of control signals u_j and θ_j parameters require the **complete** knowledge of the system's state for the interval T_i in which a threshold violation has happened. For example, consider a system with three nodes, $\{N_1, N_2, N_3\}$, in which only two of the nodes, i.e. $\{N_2, N_3\}$, observe threshold violations. The controller requires the state from all the three nodes to compute the control signals. Using the same example, in a TDMA-based communication scheme in which each node is assigned to a pre-defined time slot S_j , node N_1 is precluded from transmitting its state by being unable to be informed about the threshold violations of N_2 and N_3 . To overcome these limitations, SDC-TDMA introduces a new set of time slots S_i^v , the V-slots (see Figure 4a).

1) Violations Slots S_j^v (V-slots): In the beginning of every T_i , each node retrieves a measurement and evaluates Equation (9). Then, the result of each threshold v_j is transmitted by the corresponding node N_j to the controller at time slot S_j^v .

2) Measurement Slots S_j^x (X-slots): In the beginning of every S_j^x in X-slots, each node N_j asks the controller, by sending an a_j request, whether a threshold violation was observed in the V-slots. If no threshold violation occurred, the sensor node sleeps immediately until the next interval T_{i+1} (gray box in Figure 4a). Otherwise, each node transmits each state x_j to controller, wait for the delay d_c and actuation slots, U-slots, follow.

3) Delay d_c & Actuation Slots S_j^u (U-slots): Similar to the C-TDMA approach, after a delay d_c , each node requests the new control signal u_j from the controller. The u_j and the new threshold parameters θ_j , which is being calculated based on Equation (10), are being piggybacked into the acknowledgement messages of U-slots.

Based on the above, SDC-TDMA sacrifices channel availability and increases the minimum interval length, T_{min} and consequently the system's maximum delay, by adapting V-slots into the TDMA scheme. However, in the case of threshold violation absence, the communication is being minimized significantly by avoiding the transmission of state x_j and the entire execution of U-slots.

D. ADC-TDMA and PADETC

Similar to PSDETC, the PADETC approach transfers the communication decision making from the controller down to the sensor/actuator nodes. Additionally, due to its asynchronous feature, this approach increases the communication savings by avoiding the state transmission x_j from every node N_j in every interval T_i . The only overhead in the communication is the η_j update based on Equation (14) and transmission to N_j . The value of η_j is being piggybacked with the control signal u_j in the acknowledgement message.

Specifically, the architecture of ADC-TDMA is similar to C-TDMA and consists of sensing task, X-slots, d_c delay, and U-slot (see Figure 4b). In a S_j^x slot, the node N_j evaluates the threshold of Equation (13). In the case of no threshold violation, the node N_j skips the communication and returns to sleep mode until S_j^u . For example, the communication in gray boxes of Figure 4b can be avoided completely or partially depending on the violations. Otherwise, N_j transmits to the controller: x_j in PADETCabs or the increment m_j in PADETCrel (see Section II-D). Then, the controller computes the appropriate control signals and updates the local and global η based on Equation (14) by using **only** the available x_j states.

In the U-slots, every node has to send a r_j request message to the controller, in order to be notified about a possible threshold violation from another node. Therefore, the violation of at least one threshold causes the update of u_j and η_j to be sent to every actuator node. The values of u_j and η_j are piggybacked to the acknowledgement message.



(a) WaterBox Testbed.



(b) The schematic structure of the WaterBox.

Figure 5: WaterBox evaluation platform.

IV. EVALUATION PLATFORM: WATERBOX

Smart water networks have been used as a proof of concept for our proposed framework. The WaterBox platform (see Figure 5) is a scaled version of such a water network [35] and developed to demonstrate real time monitoring and control by adapting innovative communication theories and control methodologies.

In this paper, our aim is to demonstrate the event-triggered techniques on possible practical relative setups. Therefore, WaterBox was used as evaluation platform for our proposed ETC techniques and communication schemes. In the future, the same infrastructure will allow us to evaluate nonlinear event-triggered mechanisms.

A. WaterBox infrastructure

A Water supply network structure consists of three individual layers: (a) storage and pumping, (b) water supply zones and District Meter Areas (DMAs), and (c) end users (water demand). While valves control flows and pressures at fixed points in the water network, pumps pressurise water to overcome gravity and frictional losses along supply zones, which are divided into smaller fixed network topologies (in average 1500 customer connections) with permanent boundaries, DMAs. The DMAs are continuously monitored with the aim to enable proactive leakage management, simplistic pressure management, and efficient network maintenance. WaterBox was designed to support this architecture as follows:

1) Water Storage and Pumping: The structure of the WaterBox is shown as Fig. 5b. The WaterBox has a lower tank (i.e. ground, soil), an upper tank (i.e. reservoir, lake) and three small tanks (i.e. DMAs). The lower tank collects water from small tanks, and supplies water to the upper tank by an underwater bilge supply pump. This supply pump can supply enough water as the system requires. An assistant bilge pump and a new powerful pump are installed in series inside and after the upper tank respectively, and supply water to the small tanks. When the small tanks require more water supply, the assistant pump and powerful pump work together. When the small tanks require less water supply, only the assistant weak pump works. This behaviour emulates the day and night pumping operation of a water network in which the demand changes dramatically.



Figure 6: WaterBox sensor/ actuator node.

2) Water Supply & Sensor/Actuator Node: The water from the powerful pump flows into three small 'DMA' tanks via a pipe network. For the inlet each tank, a sensor/actuator node (see Figure 6), based on the Intel Edison development board [46], controls the water flow though a motorized gate valve, so-called in-valve, and monitors the water flow, pressure (before and after in-valve) and the in-tank water level. Further, a turbine (flow-based energy harvester) is installed before each in-valve to harvest energy. To capture the total energy consumption of each sensor/actuator node, a custom made sensor module was created.

Remark. In the WaterBox infrastructure, the sensors and actuator of each inlet are connected to the same node. However, our proposed communication schemes can be applied to non-collocated infrastructures.

3) Water Demand Emulation: At the bottom of each small tank, there is an opening which enables the emulation of water consumption. A gate valve, so-called out-valve, is installed after each opening and can be controlled by a sensor/actuator

node. The control of out-valves changes the outlet flow rate and facilitates the emulation of user's random water consumptions (i.e. external disturbance).



Figure 7: Local controller visualization application.

4) Base Station (Controller): Every sensor node is connected to a local isolated WiFi network ³. A laptop is used as a controller or base station and hosts a visualization application (see Figure 7) which presents at real time the current state of the system, allows the manual control of actuators, logs the retrieved messages, and enables our proposed communication schemes and ETC scenarios per experiment. Additionally, due to lack of an indoor GPS time synchronization, a NTP server is running in the local controller and ensures less than millisecond time synchronization accuracy among the nodes. To avoid the communication overhead of the NTP approach, each node executes the synchronization process only at the beginning of each experiment.

B. System Identification & Modelling

We apply Grey-Box identification [47] to generate the system model and to find the uncertain parameters. A first principles model is obtained following [48]. We identify independently models under both mode 1: only the assistant pump works and mode 2: both pumps work. Using the Matlab cftool, we generate fitting curves for the gate valve coefficient of each in-valve, the turbine efficiency, and the pump efficiency. These curves are used to compute the first principles model. Since our aim is to stabilize the water level of each tank $j \in \{1, 2, 3\}$ at the desired height h'_j , the model is linearised around this height. In this process, in order to simplify the simulation of the user water consumption, we keep the out-valves open, thus, constant out flow rates can be assumed.

V. HYBRID CONTROLLER DESIGN

To evaluate the proposed ETC-based communication schemes, the following **control scenario** was used: "Control in-valves to stabilize the water level of the small 'DMA' tanks to a certain level ensuring pressure and flow bounds. Enable mode 2 (weak and powerful pump) only if the system is away from the target levels. Switch to mode 1 (weak pump) only

³The isolation was achieved by disabling SSID operation (broadcast of WiFi availability to new users) from the router and selecting the low occupied communication channel for the nodes based on spectrometer experiments

when the system is close to the reference state to guarantee efficient low pressure and flow operation."

In the design of the controller, the following limitations need to be considered:

- Saturation of the actuators: The maximum open level of one in-valve is 360°, while the minimum is 0°.
- Actuator quantization: Due to the limitation of the valve's control components, their open levels can only be changed in steps of 10°. Therefore, small disturbances may result in dramatic changes of actuations.
- Over-pressure protection: Due to mechanical limitations of the pipe network, there is a maximum allowable pressure for the pipe network.

Since the height of the water levels have a direct effect on the Quality of Service (QoS), the closed-loop system requires a fast response; however, since the size of the small tanks are limited, the overshoot should simultaneously be constrained. Experiments show that, in mode 2, the pipe network may be over pressured, when the open level of the in-valves, defined by α_i^{in} , cannot satisfy:

$$\sum_{j=1}^{3} \alpha_j^{in} \ge 180^{\circ}.$$
 (19)

Overshoot and disturbances could make condition (19) be violated. While in mode 1, there is no such constrains, that is, even all three in-valves are totally closed, the pipe network will not be over pressured. Therefore, filling the small tanks in mode 2 and switching to mode 1 when (19) is violated is required. Also experimentally, we observe that, when the system is in mode 1, the pump may not provide enough water supply to the small tanks even at the maximum open level, i.e. $\alpha_j^{in} = 360^\circ$, $\forall j \in \{1, 2, 3\}$. Therefore, switching back to mode 2 when the water in the tanks reaches some pre-defined low levels is necessary. To support this mode switching, we define $\underline{h} := \begin{bmatrix} \underline{h}_1 & \underline{h}_2 & \underline{h}_3 \end{bmatrix}^{\mathrm{T}}, \underline{h}_j < h'_j, j \in \{1, 2, 3\}$, as the lower water levels. If $\exists j \in \{1, 2, 3\}$ such that $h_j(t) \leq \underline{h}_j$, the system switches from mode 1 to mode 2. With carefully chosen \underline{h}_i and properly designed controllers, this violation can only happen in mode 1. Further analysis shows that, (19) can only be violated when $h_j(t) > h'_j$, which together with the fact that $\underline{h}_i < h'_i$ precludes Zeno behaviour.

Let $\vartheta \in \{1,2\}$ represents the corresponding system mode. The linearised switched model and switched controller of WaterBox are described by:

$$\xi(t) = A(\xi(t) + h') + B_{\vartheta}v(t), \ \vartheta = 1, 2,$$
(20)

$$v(t) = S(-K_{\vartheta}\xi(t) + \bar{\alpha}_{\vartheta}^{in}), \, \vartheta = 1, 2,$$
(21)

where $\xi(t) = \begin{bmatrix} \xi_1(t) & \xi_2(t) & \xi_3(t) \end{bmatrix}^{\mathrm{T}}, \xi_j(t) := h_j(t) - h'_j, j = 1, 2, 3$ are the system states, $h_j(t) \in \mathbb{R}$ are the water levels, and $h'_j \in \mathbb{R}$ are the reference water levels with $h' = \begin{bmatrix} h'_1 & h'_2 & h'_3 \end{bmatrix}^{\mathrm{T}}; v(t) = \begin{bmatrix} v_1(t) & v_2(t) & v_3(t) \end{bmatrix}^{\mathrm{T}}, v_j(t) := \alpha_j^{in}, j = 1, 2, 3$ are the system control inputs, and $\bar{\alpha}_{\vartheta}^{in}$ are the equilibrium open levels of the in-valves per operation mode $\vartheta; S$ is a map $\mathbb{R}^m \to \mathbb{R}^m$ representing actuator saturation and quantization, that is $S(s_j) := \max\{\min\{10|10^{-1}s_j|, 360^\circ\}, 0^\circ\}.$

Then, the WaterBox hybrid controller state automaton is illustrated in Figure 8.



Figure 8: Hybrid controller state automaton.

From Grey-Box identification procedure, the system parameters are defined as follows. Due to the physical structure of the tanks and the low sensitivity of the flow meters, the flow rates are identified as constants, i.e:

$$A(\xi(t) + h') = -10^{-4} \times \begin{bmatrix} 5.809 & 3.554 & 5.102 \end{bmatrix}^{\mathrm{T}}$$

And

$$B_{1} = 10^{-5} \times \begin{bmatrix} 0.1436 & -0.0170 & -0.0164 \\ -0.0098 & 0.1060 & -0.0100 \\ -0.0139 & -0.0139 & 0.1492 \end{bmatrix}$$
$$B_{2} = 10^{-5} \times \begin{bmatrix} 0.7666 & -0.0493 & -0.0457 \\ -0.0274 & 0.5848 & -0.0279 \\ -0.0393 & -0.0432 & 0.7865 \end{bmatrix}$$

The controllers designed are given by:

$$K_1 = \begin{bmatrix} 99950 & 3029 & 872 \\ -3014 & 99940 & -1679 \\ -922 & 1652 & 99982 \end{bmatrix},$$

$$K_2 = \begin{bmatrix} 9998.5 & 167.1 & 41.0 \\ -166.6 & 9997.9 & -116.0 \\ -43.0 & 115.3 & 9999.2 \end{bmatrix}.$$

The designed controller is stable in both mode 1 and 2 because $-B_1K_1$ and $-B_2K_2$ are Hurwitz matrices. Further, due to the long dwell time of the system, the closed loop retains stable. Given $h'_j = 0.06$ and $\underline{h}_j = 0.03$, $\forall j \in \{1, 2, 3\}$, $\bar{\alpha}_1^{in}$ and $\bar{\alpha}_2^{in}$ are computed by solving $A(\xi(t) + h') + B_\vartheta \bar{\alpha}_\vartheta^{in} = 0$:

$$\bar{\alpha}_1^{in} = \begin{bmatrix} 503.5950\\422.4378\\428.5839 \end{bmatrix}, \ \bar{\alpha}_2^{in} = \begin{bmatrix} 84.5099\\68.2069\\72.8442 \end{bmatrix}.$$

Since $A(\xi(t) + h')$ is compensated by $B_{\vartheta}\bar{\alpha}_{\vartheta}^{in}$, the A in (1) can be treated as a zero 3×3 matrix. For the presented event-triggered mechanisms, once the inequalities shown in (8), (11), and (17) are feasible, the system is stable either if A = 0 or $A \neq 0$. However, the specific dynamics may not result in a large difference regarding the effects of ETC on communications. In our future work, further analysis and tests will be conducted with different system dynamics for more conclusive results. Note that, since the linearized model, switching condition, and input quantization are the same for all the event-triggered mechanisms, the comparison is fair.

VI. EVALUATION

This section summarizes the experimental results of more than 400 experiments conducted in WaterBox to evaluate our proposed communication schemes for the different ETC strategies. Each experiment executes the same control scenario (as described in Section V) and the total process lasts between 7 and 10 minutes, including the water state initialization, the execution of experiment, and data logging from sensor/ actuator nodes and local controller.

A. Evaluation Setup

Table I: Communication parameter evaluation setup.

	Parameter	Value	Description			
		36 Bytes	Node ID			
			Timestamp (in msec)			
			Inlet pressure			
			Outlet pressure			
	x_{j}		Flow rate			
Packet	5		Total water volume			
Size			Distance from surface			
			Energy consumption			
			Energy harvesting			
	$Ack - r_j, a_j$	1 Byte	0 or 1 — Node ID			
	u_j, η_j, θ_j	2 Bytes	Control signal and			
			DETC parameters			
	m_j	4 Bytes	State delta			
Time Duration	S_{i}^{x}	80 msec	X slot size			
	S_j^u, S_j^v	50 msec	U and V slot size			
	d_c	10 msec	Control decision delay			
	d	5	Threshold violation			
	a_g	5 msec	decision delay			
	Guard slot	1 msec	Forced task			
			termination time			

The proposed communication protocols of Section III were deployed to the WaterBox sensor/actuator nodes by wrapping the functionality of the Intel Edison WiFi module. Table I presents the configuration of the communication parameters. Based on the predefined packet sizes of the specific hardware infrastructure, a set of experiments was conducted to determine reliable time slot and guard delay sizes.

Table II: Parameters of triggering strategies.

Method	T (sec)	Parameter	Value		
TTC	0.5 , 1, 2	-	-		
PETC	0.5 , 1, 2	σ	0.05 0.1 0.2		
PSDETC	1, 2	0	0.05, 0.1, 0.2		
PADETC	0512	μ	0.75, 0.95		
(abs & rel)	0.0, 1, 2	Q	85 , 120		

Based on the Table I timing parameters and the Section III time slot analysis, the minimum interval size T_{min} for C-TDMA and and ADC-TDMA has to be more than 406 msec while for SDC-TDMA more than 564 msec (because of the V-slots). Thus, we evaluate TTC, PETC, and PADETC (with absolute or reference value) with interval size T = 0.5, 1, 2 and T = 1, 2 sec for PSDETC. The selected interval sizes and the rest parameters of the ETC strategies are listed in Table II. The σ and ρ ETC parameters are chosen by finding feasible solutions of the corresponding algorithms (8) and (17), while

 μ is tuned experimentally. Note that, Assumption 1 holds for all those T listed in Table II.

In the first set of experiments, we examine the impact of the ETC parameters (σ , μ , and ρ) to the performance of the system. A fixed interval size T = 1 was used with all the different combinations of ETC parameter values of Table II. Another set of experiments was conducted to explore the effect of T in the behaviour of the system. Keeping $\sigma = 0.2$, $\mu = 0.95$, and $\rho = 85$ constant, all the experiments were reexecuted with T = 0.5 and T = 2 (Table II bold text). To ensure the validity of the evaluation results, each experiment was repeated 10 times⁴ for each different combination of ETC parameters and T. Mean values are used to illustrate the evaluation results. The data was captured from the nodes and controller for the period of time between the beginning of each experiment ($t_0 = 0$) until a fixed end time ($t_{end} = 110s$), which guarantees the system turns to mode 1 and converges to steady state, denoted T_{exp} .

B. Experimental Results



Figure 9: Experimental results. Note that, for SETC, the maximum event-interval of small tank 2 is 66 sec.

In this section we compare TTC, PETC, PSDET, PADETabs and PADETrel experimental results, in terms of:

- *Water Level Overshoot:* the maximum water level during the experiment. This parameter indicates the system's maximum state overshoot which is critical for water network asset safe operation.
- Switching Time (t_{sm}) : the duration between experiment start time t_0 and first switch mode time t_{sm} , as described

⁴The number of experiment repetitions was selected experimentally by analysing the variance of the results (i.e. under 2% of mean).

in condition (19). The time to mode switching is employed as an estimate of the system settling time (due to its ease of detection in our setup).

- *Sleep Time:* the total sleep time of all the nodes. This parameter evaluates the use of the bandwidth and CPU in the sensor/actuator node.
- Discharge (Energy Consumption): our custom made sensor module retrieves current measurements c_n in mA at a fixed frequency of 10kHz. The energy consumption of a specific time period Δt in seconds and with average current measurements over this period $\langle C \rangle_{\Delta t}$ can derived from $E(\Delta t) = \langle C \rangle_{\Delta t} \cdot \frac{\Delta t}{3600}$. We used a hardware average to ensure the continuity of the current measurements and validated our instrument against a calibrated reference [49]. The energy consumption includes the consumption because of the communication, sensing, actuation, and idle mode. We present two discharge values, i.e. the whole discharge and discharge without sleep time. Based on these parameters, the battery lifetime of different hardware infrastructures can be implied.
- Actuations: the number of valves' changes, i.e. $\sum_{\forall t_b \in [t_0, t_{end}]} \sum_{j=1}^{3} \mathcal{Y}_j(t_b)$, where:

$$\mathcal{Y}_{j}(t_{b}) = \begin{cases} 1, \text{ if } \alpha_{j}^{in}(t_{b}) \neq \alpha_{j}^{in}(t_{b-1}) \\ 0, \text{ otherwise.} \end{cases}$$

where t_b is defined in (6). The amount of actuations indicates the lifetime of actuators which is vital for industrial deployments. For example, in water networks, an increase to the valve actuations implies fatigue enhancement of mechanical parts and frequent expensive maintenance.

- Valve Movement: the sum of valves' movement in degrees between two consecutive changes, i.e. $\sum_{\forall t_b \in [t_0, t_{end}]} \sum_{j=1}^3 |\alpha_j^{in}(t_b) - \alpha_j^{in}(t_{b-1})|$. Combined with the number of actuations, the valve movement can be used to estimate physical system lifetime.
- *Violations:* the sum of event condition violations. For each violation the local controller transmits a control signal u_j to each node i.e. three times. Therefore, the total transmitted control signal are equal to 3 times the violations. This metric indicates the communication requirements of actuators. Violations and actuations are different values because the local controller can produce the same consecutive control signal.
- State Transmissions: the sum of state x_j transmissions to local controller. This metric indicates the communication requirements of sensors. Both violations and state transmissions represents the total communication requirements of the system.

Figure 9 shows an example of raw data as captured from the nodes and the controller. Next, we analyse the energy consumption trends compared to sleep time for different hardware infrastructures, the effect of ETC parameter setup and interval length T to the performance of the system, and we aggregate the savings of ETC approaches against the vanilla scenario of TTC.

1) Energy Consumption and Sleep Time: The hardware infrastructure of a WaterBox node consumes more energy in



11



Figure 10: Impact of ETC parameters (σ, μ, ρ) in: (a) water level overshoot, (b) switching time, (c) sleep time, (d) discharge, (e) actuations, (f) valve movement, (g) violation, and (h) state transmissions.

sleep mode. During sleep mode, our process yields priority to the background tasks of the operating system which are more energy hungry. In order to generalize the results to different hardware infrastructures which support lower energy consumption during sleep mode (i.e. deep sleep), we provide the upper and a lower bounds of energy consumption. The upper bound presents the real experimental results based on our node while the lower bound represents an estimation of energy consumption of a node which supports deep sleep⁵. The need of energy consumption range can be clearly seen in Figures 11c and 11d. In spite of the sleep time increase in all cases, the upper bound of energy consumption increases proportionally (the opposite holds for the lower bound). Additionally, PSDETC is expected to consume more energy than the others because of the V-slots. However, Figures 10c and 10d illustrate the opposite trend for the upper bound (opposite for lower bound) due to the energy hungry sleep mode. Overall, PADETCabs and PADETCrel consume the least energy compared to the other approaches. In spite of the uses of the same communication scheme, PETC performs slightly better than TTC of actuation reduction (quantitative results will presented later on).

2) *Effect of ETC Parameters:* Figure 10 presents the effect of different parameters, e.g. σ , ρ , μ with the same interval length T = 1. The experiment results follow the trends shown in the theory. In PETC and PSDETC, a smaller σ forces the system to be more conservative and leads to more event condition violations (Figure 10g) and consequently to more

actuation (Figure 10e) and energy consumption (Figure 10d). For the same reason, in the decentralized PSDETC, the state transmission reduces with bigger σ (Figure 10h).

In PADETC, a bigger ρ has similar effect as a smaller σ in PETC. This can be clearly seen in Figure 10e and 10g, in which bigger ρ causes more actuations and violations respectively. A bigger μ can result in more frequent threshold updates, but maintains the threshold less conservative, and thus, the sampling errors can be enlarged. Additionally, Figure 10g shows that μ has greater impact on violations than σ and ρ parameters.

3) Impact of Interval Length Selection: Figure 11 illustrates the impact of different interval lengths, in which the same pre-designed Lyapunov converge rate can be guaranteed, for the same set of rest of the parameters, e.g. σ , ρ , μ . It can be clearly seen in Figure 11 that smaller interval T results in better performance but worse energy consumptions. The water level overshoots are almost the same because of the actuator quantization. Larger sampling times always result in longer convergence time and longer sleeping times. Similarly, the upper bound discharge indicates this trend; longer sleep time leads to higher energy consumption due to the energy hungry operating system background tasks. Oppositely, the lower bound of discharge shows that hardware infrastructures with deep sleep consume significant lower energy for larger interval T due to long sleeping time.

4) Savings Compared to TTC: Table III and IV show the total savings of different ETC techniques against TTC for the time period $period_1 = [0, t_{end}]$ (total experiment time) and $period_2 = [0, t_{sm}]$ (time until switching mode) respectively. We provide this data separately due to the existence of the

⁵We calculated the lower energy consumption by subtracting the energy consumption during sleep mode from the total



Figure 11: Impact of interval length T in: (a) water level overshoot, (b) switching time, (c) sleep time, (d) discharge, (e) actuations, (f) valve movement, (g) violation, and (h) state transmissions.

Table III: Savings compared to TTC (%) total experiment time, i.e. $[0, t_{end}]$, with $\sigma = 0.2, \rho = 85$, and $\mu = 0.95$

Approach	Water Level Overshoot	Switching Time	Discharge	Discharge with Deep Sleep	Actuations	Aggr. Valve Movement	Violations	State Transmissions
PETC	3.18	-0.69	0.97	1.1	18.6	-1.7	42.8	0
PSDETC	1.24	-0.55	11.03	-57.6	8.2	1.5	21.5	21.5
PADETC (abs)	2.44	3.47	4.74	6.9	27.2	7.5	44.8	51.6
PADETC (rel)	-19.72	-20.53	3.28	13.2	9.7	30.5	51.8	56.0

Table IV: Savings compared to TTC (%) until mode switching time, i.e. $[0, t_{sm}]$, with $\sigma = 0.2, \rho = 85$, and $\mu = 0.95$

Approach	Water Level Overshoot	Switching Time	Discharge	Discharge with Deep Sleep	Actuations	Aggr. Valve Movement	Violations	State Transmissions
PETC	3.15	-0.69	1.34	2.4	30.3	17.3	55.2	-0.7
PSDETC	1.67	-0.55	10.97	-66.9	10.4	8.3	14.6	14.6
PADETC (abs)	3.02	3.47	9.22	11.9	34.7	24.1	57.0	63.9
PADETC (rel)	-19.72	-20.53	-15.23	-4.5	14.4	22.6	49.1	54.5

switched controller and the different behaviour of the two modes.

In *period*¹ PETC performs similarly to TTC with the difference of reduced actuations and violations by 18.6% and 42.8% respectively. In spite the saving, PETC causes more valve movements than TTC. The PSDETC is more conservative than the centralized PETC, with a result, the lower savings in terms of violations. However, PSDETC reduces the valve movements and the state transmissions due to the decentralized architecture. PADETCabs outperforms all the other approaches because of the asynchronous behaviour, reducing significantly the violations, state transmissions and actuations by achieving 44.8%, 51.6%, and 27.2% savings respectively. PADETCrel occurs similar actuation and communication saving with PADETCrel but with the trade-off of lower performance in terms of water level overshoots and

switching time. As has been described in Section II, this happens because the PADETC with reference value updates introduces an extra error, known as maximum dynamic quantization error. However, this extra error allows this triggering mechanism to be more robust against noise than any of the other mechanisms with pre-designed maximum dynamic error.

In $period_2$, some ETC approaches deviate compared to the total savings. For example, in PETC approach, $period_2$ reveals higher actuation savings than $period_1$. The reason is that in mode 1, the weak pump is unable to supply the tanks with enough water and the system deviates from steady state continuously. Thus, event condition violations are being increased and often large valve movements are required. PSDETC and PADETCabs have a smaller overshoot than the other ETC approaches. Again PADETCabs outperforms the other ETC approaches achieving outstanding violation (57%) and actuation (35%) savings.

VII. CONCLUSION

In this paper, we have proposed duty-cycling of the sensing and actuator listening activities and enabled decentralized ETC techniques introducing innovative communication schemes. Specifically, we designed and implemented three new MAC layers, which enable the application of four different periodic centralized and decentralized event-triggered control approaches. By implementing our proposed communication schemes in the WaterBox testbed [35], we provided experimental results from more than 400 experiments.

Based on the experimental results, ETC approaches can introduce considerable benefits into industrial deployments. Due to the outstanding decrease of actuations either in number (up to 35%) or size (i.e. for valve movement up to 24%), the ETC techniques can increase the robustness, resilience, and lifetime of physical plants and actuators significantly. This increase can lead to significant maintenance cost reduction by postponing expensive replacements of plant assets.

WaterBox consists of energy hungry sensor/ actuator nodes to allow computational intensive algorithm deployments. An optimal hardware infrastructure will reduce the energy consumption even more than the evaluation results. Intuitively, the level of energy reduction will be closer to threshold violations (up to 57%) and state transmission (up to 64%) savings which indicate the actuator and sensors communication requirement respectively.

An additional benefit of applying periodic centralized or decentralized ETC approaches is the reduction of sensing rate. Continuous measurement retrieval from high energy demanding sensors (e.g. the water content sensor [50] which consumes 570 mJ per measurement) may lead to higher energy consumption than the communication process (e.g. low power wide area communication modules in [42] which consumes 1.5 to 42 J per 10 bytes). Further, based on our experimental results, higher sensing rates do not guarantee higher control performance. As future work, we will examine the aperiodic sensing scheduling over ETC techniques and the impact to the co-existing high sample rate algorithms for anomaly detection and validation. While in this paper we focus on smart water networks, the proposed framework can be applied to a variety of Cyber-Physical Systems such as Smart Grids, Smart Transportation Systems and Automated Agriculture.

ACKNOWLEDGMENT

This work forms part of the Big Data Technology for Smart Water Networks research project funded by NEC Corp, Japan and partly supported by China Scholarship Council (CSC).

REFERENCES

- SWIG, "Data standards and protocols for real-time communications in the water industry," http://www.swig.org.uk/past-swig-events/2014-2/, 2015, online; accessed 22-June-2015.
- [2] P. Tabuada, "Event-triggered real-time scheduling of stabilizing control tasks," *IEEE Trans. Autom. Control*, vol. 52, no. 9, pp. 1680–1685, 2007.
- [3] X. Wang and M. D. Lemmon, "Event-triggering in distributed networked control systems," *IEEE Trans. Autom. Control*, vol. 56, no. 3, pp. 586– 601, 2011.

- [4] W. Heemels, M. Donkers, and A. R. Teel, "Periodic event-triggered control for linear systems," *IEEE Trans. Autom. Control*, vol. 58, no. 4, pp. 847–861, 2013.
- [5] M. Mazo Jr. and P. Tabuada, "Decentralized event-triggered control over wireless sensor/actuator networks," *IEEE Trans. Autom. Control*, vol. 56, no. 10, pp. 2456–2461, 2011.
- [6] M. Mazo Jr. and M. Cao, "Asynchronous decentralized event-triggered control," *Automatica*, vol. 50, no. 12, pp. 3197–3203, 2014.
- [7] B. A. Khashooei, D. J. Antunes, and W. Heemels, "An event-triggered policy for remote sensing and control with performance guarantees," in *Proc. IEEE CDC*, 2015, pp. 4830–4835.
- [8] J. Sandee, P. Visser, and W. Heemels, "Analysis and experimental validation of processor load for event-driven controllers," in *Proc. IEEE CACSD*, 2006, pp. 1879–1884.
- [9] W. Heemels, D. Borgers, V. Dolk, R. Geiselhart, and S. Heijmans, "Constructions of lyapunov functions for large-scale networked control systems with packet-based communication," in *Proc. ECC*, 2016, pp. 936–938.
- [10] B. V. Eekelen, N. Rao, B. A. Khashooei, D. Antunes, and W. Heemels, "Experimental validation of an event-triggered policy for remote sensing and control with performance guarantees," in *Proc. EBCCSP*, 2016.
- [11] D. Lehmann and J. Lunze, "Extension and experimental evaluation of an event-based state-feedback approach," *Control Engineering Practice*, vol. 19, no. 2, pp. 101–112, 2011.
- [12] M. Sigurani, C. Stöcker, L. Grüne, and J. Lunze, "Experimental evaluation of two complementary decentralized event-based control methods," *Control Engineering Practice*, vol. 35, pp. 22–34, 2015.
- [13] F. Altaf, J. Araújo, A. Hernandez, H. Sandberg, and K. H. Johansson, "Wireless event-triggered controller for a 3d tower crane lab process," in *Proc. IEEE MED*, 2011, pp. 994–1001.
- [14] M. Lemmon, "Event-triggered feedback in control, estimation, and optimization," in *Networked Control Systems*. Springer, 2010, pp. 293– 358.
- [15] S. Trimpe and R. D'Andrea, "An experimental demonstration of a distributed and event-based state estimation algorithm," *IFAC*, vol. 44, no. 1, pp. 8811–8818, 2011.
- [16] L. Orihuela, P. Millán, C. Vivas, and F. R. Rubio, "Suboptimal distributed control and estimation: application to a four coupled tanks system," *International Journal of Systems Science*, vol. 47, no. 8, pp. 1755–1771, 2016.
- [17] T. Blevins, M. Nixon, and W. Wojsznis, "Event based control applied to wireless throttling valves," in *Proc. IEEE EBCCSP*, 2015, pp. 1–6.
- [18] B. Boisseau, S. Durand, J. Martinez-Molina, T. Raharijaona, and N. Marchand, "Attitude control of a gyroscope actuator using eventbased discrete-time approach," in *Proc. IEEE EBCCSP*, 2015, pp. 1–6.
- [19] J. Araújo, M. Mazo Jr., A. Anta, P. Tabuada, and K. H. Johansson, "System architectures, protocols and algorithms for aperiodic wireless control systems," *IEEE Trans. Ind. Informat.*, vol. 10, no. 1, pp. 175– 184, 2014.
- [20] M. Miskowicz and J. Lunze, "Event-based control: Introduction and survey," in *Event-Based Control and Signal Processing*. CRC Press, 2015, pp. 3–20.
- [21] R. Blind and F. Allgöwer, "On time-triggered and event-based control of integrator systems over a shared communication system," *Mathematics* of Control, Signals, and Systems, vol. 25, no. 4, pp. 517–557, 2013.
- [22] A. Cervin and T. Henningsson, "Scheduling of event-triggered controllers on a shared network," in *Proc. IEEE CDC*, 2008, pp. 3601–3606.
- [23] C. Ramesh, H. Sandberg, and K. H. Johansson, "Stability analysis and design of a network of event-based systems," arXiv preprint arXiv:1401.5004, 2014.
- [24] B. Demirel, V. Gupta, D. E. Quevedo, and M. Johansson, "On the trade-off between control performance and communication cost in eventtriggered control," arXiv preprint arXiv:1501.00892, 2015.
- [25] C. Ramesh, H. Sandberg, and K. H. Johansson, "Steady state performance analysis of multiple state-based schedulers with csma," in *Proc. IEEE CDC-ECC*, 2011, pp. 4729–4734.
- [26] R. Blind and F. Allgöwer, "Analysis of networked event-based control with a shared communication medium: Part i-pure aloha," *Proc. IFAC*, vol. 44, no. 1, pp. 10092–10097, 2011.
- [27] M. Vilgelm, M. H. Mamduhi, W. Kellerer, and S. Hirche, "Adaptive decentralized mac for event-triggered networked control systems," in *Proc. ACM HSCC*, 2016, pp. 165–174.
- [28] R. Obermaisser and W. Lang, "Event-triggered versus time-triggered real-time systems: A comparative study," *Event-Based Control and Signal Processing*, p. 59, 2015.
- [29] M. Mazo Jr. and A. Fu, "Decentralized event-triggered controller implementations," *Event-Based Control and Signal Processing*, p. 121, 2015.

- [30] F. Calì, M. Conti, and E. Gregori, "Dynamic ieee 802.11: design, modeling and performance evaluation," in *International Conference on Research in Networking*. Springer, 2000, pp. 786–798.
- [31] G. Miao, J. Zander, K. W. Sung, and S. B. Slimane, Fundamentals of Mobile Data Networks. Cambridge University Press, 2016.
- [32] N. Abramson, "The aloha system: another alternative for computer communications," in *Proc. ACM Joint Computer Conference*, 1970, pp. 281–285.
- [33] IEEE, "IEEE 802.15.4 Standard: Wireless Medium Access Control (MAC) and Physical Layer (PHY) Specifications for Low-Rate Wireless Personal Area Networks (WPANs)," http://www.ieee802.org/15/pub/ TG4.html, 2006, [Online; accessed 12-September-2016].
- [34] H. C. Foundation, "WirelessHART Data Sheet," http://www.hartcomm2. org, 2007, [Online; accessed 12-September-2016].
- [35] S. Kartakis, E. Abraham, and J. A. McCann, "Waterbox: A testbed for monitoring and controlling smart water networks," in *Proc. ACM CysWater*, 2015, p. 8.
- [36] P. Kolios, G. Ellinas, C. Panayiotou, and M. Polycarpou, "Energy efficient event-based networking for the internet of things," in *Proc.* of *IEEE WF-IoT*, 2016, pp. 1–6.
- [37] A. Fu and M. Mazo, "Periodic asynchronous event-triggered control," in Proc. of IEEE CDC, 2016, pp. 1370–1375.
- [38] H. Kwakernaak and R. Sivan, *Linear optimal control systems*. Wiley-Interscience New York, 1972, vol. 1.
- [39] E. D. Sontag, "Input to state stability: Basic concepts and results," in Nonlinear and optimal control theory. Springer, 2008, pp. 163–220.
- [40] S. P. Boyd, L. El Ghaoui, E. Feron, and V. Balakrishnan, *Linear matrix inequalities in system and control theory*. SIAM, 1994, vol. 15.
- [41] R. Goebel, R. G. Sanfelice, and A. R. Teel, *Hybrid Dynamical Systems: modeling, stability, and robustness.* Princeton University Press, 2012.
- [42] S. Kartakis, B. D. Choudhary, A. D. Gluhak, L. Lambrinos, and J. A. McCann, "Demystifying low-power wide-area communications for city iot applications," in *Proc. ACM WiNTECH '16*, 2016, pp. 2–8.
- [43] Spectracom, "GPS Clock Synchronization," http://spectracom.com/ resources/essential-education/gps-clock-synchronization, 2008, [Online; accessed 12-September-2016].
- [44] A. Hoskins and I. Stoianov, "Infrasense: A distributed system for the continuous analysis of hydraulic transients," *Procedia Engineering*, vol. 70, pp. 823–832, 2014.
- [45] TI, "CC430F5137 Communication Module," http://www.ti.com/product/ CC430F5137, 2016, [Online; accessed 12-September-2016].
- [46] Intel, "Intel Edison board," http://www.intel.com/content/www/us/en/ do-it-yourself/edison.html, 2015, online; accessed 14-September-2016.
- [47] L. Ljung, System Identification: Theory for the User, ser. Prentice Hall information and system sciences series, 1999.
- [48] T. M. Walski, D. V. Chase, D. A. Savic, W. Grayman, S. Beckwith, and E. Koelle, "Advanced water distribution modeling and management," 2003.
- [49] Keysight Technologies, "N6705B DC Power Analyzer," http://www.keysight.com/en/pd-1842303-pn-N6705B/ dc-power-analyzer-modular-600-w-4-slots?nid=-35714.937221.00& cc=GB&lc=eng, 2016, [Online; accessed 12-October-2016].
- [50] Delta-T Devices, "WET-2 Sensor," http://www.delta-t.co.uk/ product-display.asp?id=940, 2016, [Online; accessed 12-October-2016].